

2016 Annual Water Quality Report
(Testing Performed January through December 2015)

CALERA WATER WORKS

10947 Hwy 25
Calera, AL 35040
Phone 205-668-3511
Fax 205-668-3621

We are pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water.

Number of Customers	Approximately 7470 service connections	
Water Source	Four groundwater wells producing from Cameron Bill dolomite	
Water Treatment	Chlorination, membrane filtration	
Storage Capacity	7 tanks with a total capacity of 6,730,000 gallons	
Additional Connections	Emergency connection with Montevallo Water Works & Alabaster Water	
Board Members	Jon Graham, Chairman	Joe Dorris, Member
	Chris Bunn, Vice Chairman	Preston Nail, Member
	Harold Cole, Member	

Water Quality Protection

In compliance with the Alabama Department of Environmental Management (ADEM), **Calera Water Works** has developed a Source Water Assessment plan that will assist in protecting our water sources. The assessment has been performed, public notification has been completed, and the plan has been approved by ADEM. All of the potential contaminants sited in our study area were considered low or medium. A copy of the report is available in our office for review during regular business hours, or you may purchase a copy upon request for a nominal reproduction fee.

Calera Water Works routinely completes a water storage facility inspection plan and utilizes a Bacteriological Monitoring Plan. Chlorine residual is routinely tested by our technicians at several locations throughout our distribution system to ensure that there is an adequate disinfection residual to protect your drinking water. Results show that the required minimum free chlorine residual level of 0.2 mg/L is maintained. We have also established a Cross-Connection Policy to insure safe drinking water for our customers.

Please help us make these efforts worthwhile by protecting our source water. Carefully follow instructions on pesticides and herbicides you use for your lawn and garden, and properly dispose of household chemicals, paints, and waste oil. We ask that all our customers help us protect our valuable water sources, which are the heart of our community, our way of life, and our children's futures.

Monitoring Schedule

Calera Water Works routinely monitors for contaminants in your drinking water according to Federal and State laws, using EPA approved methods and a State certified laboratory. The Alabama Department of Environmental Management (ADEM) allows us to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently.

Constituents Monitored	Date Monitored
Inorganic Contaminants	2014
Lead/Copper	2013
Microbiological Contaminants	current
Nitrates	2015
Radioactive Contaminants	2015
Synthetic Organic Contaminants (including herbicides and pesticides)	2015
Volatile Organic Contaminants	2014
Disinfection By-products	2015
Cryptosporidium	2009
Unregulated Contaminant Monitoring Rule 3 (UCMR3) contaminants	2014

General Information

All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. MCL's, defined in a List of Definitions in this report, are set at very stringent levels. To understand the possible health effects described for many regulated constituents, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and radioactive material, and it can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water run-off, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, storm water run-off, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water.

Some people may be more vulnerable to contaminants in drinking water than the general population. People who are immunocompromised such as cancer patients undergoing chemotherapy, organ transplant recipients, HIV/AIDS positive or other immune system disorders, some elderly, and infants can be particularly at risk from infections. People at risk should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Based on a study conducted by ADEM with the approval of the EPA a statewide waiver for the monitoring of asbestos and dioxin was issued. Thus, monitoring for these contaminants was not required.

Information about Lead

Lead in drinking water is rarely found in source water but is primarily from materials and components associated with service lines and home plumbing. Your water system is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Use *only* water from the cold-water tap for drinking, cooking, and *especially for making baby formula*. Hot water is more likely to cause leaching of lead from plumbing materials. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. These recommended actions are very important to the health of your family.

Lead levels in your drinking water are likely to be higher if:

- Your home or water system has lead pipes, or
- Your home has faucets or fittings made of brass which contains some lead, or
- Your home has copper pipes with lead solder and you have naturally soft water, and
- Water often sits in the pipes for several hours.

If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water hotline or at www.epa.gov/safewater/lead.

Questions?

If you have any questions about this report or concerning your water utility, please contact **Alan Broadhead**. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on **the third Tuesday of each month at the Calera City Hall at 4:00 p.m.**

More information about contaminants to drinking water and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (1-800-426-4791).

Detected Drinking Water Contaminants

TABLE OF DETECTED DRINKING WATER CONTAMINANTS						
Contaminants	Violation	Level	Unit	MCLG	MCL	Likely Source of Contamination
	Y/N	Detected	Msmt			
Chlorine	NO	1.86-2.63	ppm	MRDLG=4	MRDL=4	Water additive used to control microbes
Turbidity	NO	0.049	NTU	n/a	TT	Soil runoff
Alpha emitters	NO	1.0 ± 0.5	PCi/l	0	15	Erosion of natural deposits
Copper	NO	0.144* 0 > AL	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Nitrate (as Nitrogen)	NO	0.93	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
TTHM [Total trihalomethanes]	NO	RAA 6.38 1.06-18.6	ppb	0	80	By-product of drinking water chlorination
HAA5 [Total haloacetic acids]	NO	RAA 3.95 ND-9.08	ppb	0	60	By-product of drinking water chlorination
Unregulated Contaminants						
Chloroform	NO	1.59	ppb	n/a	n/a	Naturally occurring in the environment or from discharge or runoff
Bromodichloromethane	NO	1.21	ppb	n/a	n/a	Naturally occurring in the environment or from discharge or runoff
Chlorodibromomethane	NO	0.65	ppb	n/a	n/a	Naturally occurring in the environment or from discharge or runoff
Secondary Contaminants						
Chloride	NO	5.43	ppm	n/a	250	Naturally occurring in the environment or from discharge or runoff
Hardness	NO	198	ppm	n/a	n/a	Naturally occurring in the environment or as a result of treatment with water additives
pH	NO	8.05	S.U.	n/a	n/a	Naturally occurring in the environment or as a result of treatment with water additives
Sodium	NO	1.85	ppm	n/a	n/a	Naturally occurring in the environment
Sulfate	NO	1.65	ppm	n/a	250	Naturally occurring in the environment or from discharge or runoff
Total Dissolved Solids	NO	240	ppm	n/a	500	Naturally occurring in the environment or from discharge or runoff

* Figure shown is 90th percentile and # of sites above action level (1.3 ppm) = 0

Unregulated Contaminant Rule 3 (UCMR3) Contaminants Detected 2014			
Contaminants	Level Detected	Unit Msmt.	Likely Source of Contamination
Strontium	27.0-29.0	ppb	Naturally occurring in the environment or as a result of discharge
Vanadium	0.30-0.340	ppb	Naturally occurring in the environment or as a result of runoff from mining or industrial discharge
Chromium, Hexavalent	0.10-0.13	ppb	Naturally occurring in the environment or as a result of industrial discharge

DEFINITIONS

Action Level- the concentration of a contaminant that, if exceeded, triggers treatment or other requirements which a water system must follow.

Coliform Absent (ca)- Laboratory analysis indicates that the contaminant is not present.

Disinfection byproducts (DBPs)- are formed when disinfectants used in water treatment plants react with bromide and/or natural organic matter (i.e., decaying vegetation) present in the source water. Different disinfectants produce different types or amounts of disinfection byproducts. Disinfection byproducts for which regulations have been established include trihalomethanes (TTHM), haloacetic acids (HAA5), bromate, and chlorite.

Initial Distribution System Evaluation (IDSE)-a one-time study conducted by water systems to identify distribution system locations with high concentrations of trihalomethanes (THMs) and haloacetic acids (HAAs).

Locational Running Annual Average (LRAA)-yearly average of all the DPB results at each specific sampling site in the distribution system.

Maximum Contaminant Level-(mandatory language) The Maximum Allowed (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal-(mandatory language) The Goal (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL)-the highest level of a disinfectant allowed in drinking water

Millirems per year (mrem/yr)-measure of radiation absorbed by the body.

Nephelometric Turbidity Unit (NTU)-a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

Non-Detects (ND)- laboratory analysis indicates that the constituent is not present above detection limits of lab equipment.

Not Reported (NR)-laboratory analysis, usually Secondary Contaminants, not reported by water system. EPA recommends secondary standards to water systems but does not require systems to comply.

Parts per billion (ppb) or Micrograms per liter (µg/l)-one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Parts per million (ppm) or Milligrams per liter (mg/l)-one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per quadrillion (ppq) or Picograms per liter (picograms/l)-one part per quadrillion corresponds to one minute in 2,000,000,000 years, or a single penny in \$10,000,000,000,000.

Parts per trillion (ppt) or Nanograms per liter (nanograms/l)-one part per trillion corresponds to one minute in 2,000,000 years, or a single penny in \$10,000,000,000.

Picocuries per liter (pCi/L)-picocuries per liter is a measure of the radioactivity in water.

RAA-Running annual average

Standard Units (S.U.)-pH of water measures the water's balances of acids and bases and is affected by temperature and carbon dioxide gas. Water with less than 6.5 could be acidic, soft, and corrosive. A pH greater than 8.5 could indicate that the water is hard.

Treatment Technique (TT)- a required process intended to reduce the level of a contaminant in drinking water.

Variances & Exemptions (V&E)-State or EPA permission not to meet an MCL or a treatment technique under certain conditions.

Following is a list of *Primary Drinking Water Contaminants* and a list of *Unregulated Contaminants* for which our water system routinely monitors. These contaminants were *not* detected in your drinking water unless they are listed in the *Table of Detected Drinking Water Contaminants*.

STANDARD LIST OF PRIMARY DRINKING WATER CONTAMINANTS					
Contaminant	MCL	Unit of Msmt	Contaminant	MCL	Unit of Msmt
Bacteriological Contaminants			trans-1,2-Dichloroethylene	100	ppb
Total Coliform Bacteria	<5%	present or absent	Dichloromethane	5	ppb
Fecal Coliform and E. coli	0	present or absent	1,2-Dichloropropane	5	ppb
Turbidity	TT	NTU	Di (2-ethylhexyl)adipate	400	ppb
Cryptosporidium	TT	Calculated organisms/liter	Di (2-ethylhexyl)phthalate	6	ppb
Radiological Contaminants			Dinoseb	7	ppb
Beta/photon emitters	4	mrem/yr	Dioxin [2,3,7,8-TCDD]	30	ppq
Alpha emitters	15	pCi/l	Diquat	20	ppb
Combined radium	5	pCi/l	Endothall	100	ppb
Uranium	30	pCi/l	Endrin	2	ppb
Inorganic Chemicals			Epichlorohydrin	TT	TT
Antimony	6	ppb	Ethylbenzene	700	ppb
Arsenic	10	ppb	Ethylene dibromide	50	ppt
Asbestos	7	MFL	Glyphosate	700	ppb
Barium	2	ppm	Heptachlor	400	ppt
Beryllium	4	ppb	Heptachlor epoxide	200	ppt
Cadmium	5	ppb	Hexachlorobenzene	1	ppb
Chromium	100	ppb	Hexachlorocyclopentadiene	50	ppb
Copper	AL=1.3	ppm	Lindane	200	ppt
Cyanide	200	ppb	Methoxychlor	40	ppb
Fluoride	4	ppm	Oxamyl [Vydate]	200	ppb
Lead	AL=15	ppb	Polychlorinated biphenyls (PCBs)	0.5	ppb
Mercury	2	ppb	Pentachlorophenol	1	ppb
Nitrate	10	ppm	Picloram	500	ppb
Nitrite	1	ppm	Simazine	4	ppb
Selenium	.05	ppm	Styrene	100	ppb
Thallium	.002	ppm	Tetrachloroethylene	5	ppb
Organic Contaminants			Toluene	1	ppm
2,4-D	70	ppb	Toxaphene	3	ppb
Acrylamide	TT	TT	2,4,5-TP(Silvex)	50	ppb
Alachlor	2	ppb	1,2,4-Trichlorobenzene	.07	ppm
Benzene	5	ppb	1,1,1-Trichloroethane	200	ppb
Benzo(a)pyrene [PAHs]	200	ppt	1,1,2-Trichloroethane	5	ppb
Carbofuran	40	ppb	Trichloroethylene	5	ppb
Carbon tetrachloride	5	ppb	Vinyl Chloride	2	ppb
Chlordane	2	ppb	Xylenes	10	ppm
Chlorobenzene	100	ppb	Disinfectants & Disinfection Byproducts		
Dalapon	200	ppb	Chlorine	4	ppm
Dibromochloropropane	200	ppt	Chlorine Dioxide	800	ppb
o-Dichlorobenzene	600	ppb	Chloramines	4	ppm
p-Dichlorobenzene	75	ppb	Bromate	10	ppb
1,2-Dichloroethane	5	ppb	Chlorite	1	ppm
1,1-Dichloroethylene	7	ppb	HAA5 [Total haloacetic acids]	60	ppb
cis-1,2-Dichloroethylene	70	ppb	TTHM [Total trihalomethanes]	80	ppb
UNREGULATED CONTAMINANTS					
1,1 – Dichloropropene	Aldicarb		Chloroform		Metolachlor
1,1,1,2-Tetrachloroethane	Aldicarb Sulfone		Chloromethane		Metribuzin
1,1,2,2-Tetrachloroethane	Aldicarb Sulfoxide		Dibromochloromethane		N - Butylbenzene
1,1-Dichloroethane	Aldrin		Dibromomethane		Naphthalene
1,2,3 - Trichlorobenzene	Bromobenzene		Dicamba		N-Propylbenzene
1,2,3 - Trichloropropane	Bromochloromethane		Dichlorodifluoromethane		O-Chlorotoluene
1,2,4 - Trimethylbenzene	Bromodichloromethane		Dieldrin		P-Chlorotoluene
1,3 – Dichloropropane	Bromoform		Hexachlorobutadiene		P-Isopropyltoluene
1,3 – Dichloropropene	Bromomethane		Isopropylbenzene		Propachlor
1,3,5 - Trimethylbenzene	Butachlor		M-Dichlorobenzene		Sec - Butylbenzene
2,2 – Dichloropropane	Carbaryl		Methomyl		Tert - Butylbenzene
3-Hydroxycarbofuran	Chloroethane		MTBE		Trichlorofluoromethane